



Ref. Certif. No.

DK-126029-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Din-Rail Switching Power Supply
Name and address of the applicant	MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN
Name and address of the manufacturer	MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN
Name and address of the factory	MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891, Taiwan
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> <a href="#">Additional Information on page 2</a>
Ratings and principal characteristics	Input:100 - 277 Vac, 2.8A, 50/60 Hz <input checked="" type="checkbox"/> <a href="#">Additional Information on page 2</a>
Trademark / Brand (if any)	MEAN WELL 
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	DRS-240-xCAN, DRS-240-x (where x can be 12, 24, 36, 48 which denoted for output voltage)
Additional information (if necessary may also be reported on page 2)	<b>Additionally evaluated to:</b> EN 62368-1:2014, EN 62368-1:2014/A11:2017 The report was revised to include technical modifications. National Differences: EU Group Differences, AU, CA, JP, NZ, US <input checked="" type="checkbox"/> <a href="#">Additional Information on page 2</a>
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	E183223-A6078-CB-1 issued on 2024-01-16

This CB Test Certificate is issued by the National Certification Body



- UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/hcbnames](http://www.ul.com/hcbnames)

Date: 2024-01-17  
Original Issue Date: 2022-04-07

Signature:  
Thomas Wilson



Ref. Certif. No.

**DK-126029-M1-UL**

**Factory(ies):**

SuZhou MEAN WELL Technology Co., Ltd.  
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town, Xiang-cheng District, Suzhou, Jiangsu 215152, China

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD HUADU BRANCH.  
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou Guangdong 510890, China

YONGDEN TECHNOLOGY CORPORATION  
345 MacArthur HighWay Tabang, Guiguinto, Bulacan 3015, Philippines

SuZhou MEAN WELL Technology Co., Ltd.  
No.269, Changping Rd, Huangdai Town Xiangcheng District, Suzhou, Jiangsu, 215152, China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED  
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058, India

**Additional Ratings:**

Model DRS-240-12, DRS-240-12CAN:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 12 Vdc, Max. 20 A  
BAT.: 12 Vdc, Max.15.4 A  
Total Power: Max. 240 W

Model DRS-240-24, DRS-240-24CAN:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 24 Vdc, Max. 10 A  
BAT.: 24 Vdc, Max. 7.7 A  
Total Power: Max. 240 W

Model DRS-240-36, DRS-240-36CAN:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 36 Vdc, Max. 6.67 A  
BAT.: 36 Vdc, Max. 5.1 A  
Total Power: Max. 240 W

Model DRS-240-48, DRS-240-48CAN:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 48 Vdc, Max. 5 A  
BAT.: 48 Vdc, Max. 3.85 A  
Total Power: Max. 240 W

**Summary of Modifications:**

- Alternate chip U561
- Update factories and National Differences
- Update critical components list and add new source of Silicon Rubber
- Add new model

**Additional information (if necessary)**



- UL Solutions (US), 333 Pflugsten Rd IL 60062, Northbrook, USA
- UL Solutions (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2024-01-17  
Original Issue Date: 2022-04-07

Signature:

Thomas Wilson



Ref. Certif. No.

**DK-126029-UL**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Din-Rail Switching Power Supply
Name and address of the applicant	MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN
Name and address of the manufacturer	MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN
Name and address of the factory	MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Input:100 - 277 Vac, 2.8A, 50/60 Hz <input checked="" type="checkbox"/> Additional Information on page 2
Trademark (if any)	MEAN WELL 
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	DRS-240-x (where x can be 12, 24, 36, 48 which denoted for output voltage)
Additional information (if necessary may also be reported on page 2)	<b>Additionally evaluated to:</b> EN 62368-1:2014, EN 62368-1:2014/A11:2017 National Difference specified in the CB Test Report <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	E183223-A6078-CB-1 issued on 2022-04-06

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2022-04-07

Signature:   
Jan-Erik Storgaard



Ref. Certif. No.

**DK-126029-UL**

**Factory(ies):**

SUZHOU MEAN WELL TECHNOLOGY CO LTD  
NO. 77, JIAN-MIN ROAD DONG-QIAO PAN-YANG IND. PARK HUANG-DAI TOWN XIANG-CHENG DISTRICT SUZHOU  
JIANGSU 215152 CHINA

MEAN WELL (GUANGZHOU) ELECTRONICS CO LTD  
NO 11 JINGU SOUTH ROAD HUADU DISTRICT GUANGZHOU GUANGDONG 510890  
CHINA

YONGDEN TECHNOLOGY CORPORATION  
345 MACARTHUR HIGHWAY TABANG, GUIGUINTO, BULACAN 3015,  
PHILIPPINES

**Additional Ratings:**

Model DRS-240-12:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 12 Vdc, Max. 20 A  
BAT.: 12 Vdc, Max.15.4 A  
Total Power: Max. 240 W

Model DRS-240-24:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 24 Vdc, Max. 10 A  
BAT.: 24 Vdc, Max. 7.7 A  
Total Power: Max. 240 W

Model DRS-240-36:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 36 Vdc, Max. 6.67 A  
BAT.: 36 Vdc, Max. 5.1 A  
Total Power: Max. 240 W

Model DRS-240-48:  
Input:100 - 277 Vac, 2.8A, 50/60 Hz  
Output: 48 Vdc, Max. 5 A  
BAT.: 48 Vdc, Max. 3.85 A  
Total Power: Max. 240 W

**Additional information (if necessary)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2022-04-07

Signature:   
Jan-Erik Storgaard